



Jyoti Ltd.

Water • Power • Progress

'Jyoti' HT Power Factor Correction Solution (HT APFC Panel - 3.6 kV to 12 kV)



Successfully Type Tested
as per IS/IEC Standard at ERDA Vadodara, India



Jyoti Limited offer HT Power Factor Correction System

To provide a effective control on capacitor bank to maintain power factor near unity under varying load conditions.

To improve system efficiency by reducing Maximum Demand under the same load conditions.


A Automatic Power Factor Correction System for Varing Load

APFC Controller automatically switches on/off number of steps of capacitor banks by continuously sensing and giving signal to switching devices to

switch on/off the capacitor steps as per requirement to achieve power factor near unity.

Features


- Indoor & Outdoor installation.
Equipped with Vacuum contactor , power capacitor units , series reactor for inrush current protection , Auto manual selection , RVT, HRC Fuses , Automatic P.F. Controller. Nos. of steps as required.
- Powder coated MS cubical construction.
- Fully type tested as per IS/ IEC STANDARDS




Panel Accessories-1 RVT




Panel Accessories-2 Reactors



Panel Accessories-3 Capacitor Bank



Jyoti Vacuum Contactor



TECHNICAL SPECIFICATION OF HT APFC PANEL.

1	Rated Voltage	3.6 /7.2/12 kV
2	Rated Frequency	50 / 60 Hzs
3	No of Phase	Three Phase , 3 / 4 wire
4	Rated APFC Output	100 KVAR to 3000 KVAR
5	Number of Capacitor steps	As required /Up to 16 Steps
6	Step Configuration	Min 100 KVAR / As required
7	Switching of Capacitor	APFC Relay with Auto / Manual mode
8	Capacitor switching device	Vacuum Contactor
9	Incoming disconnecting device	Isolator
10	Step protection	HRC Fuses
11	Current limiting device	Series Reactor
12	Installations	Indoor / Outdoor
13	Construction	MS Encloser with powder coating
14	Unbalance protection device	RVT

B Manually switched Fix Capacitor Bank

TECHNICAL SPECIFICATION OF FIXED HT CAPACITOR BANK / MANUAL SWITCHED BANK

1	Rated Voltage	3.6 /7.2/12 kV
2	Rated Frequency	50 Hzs
3	No of Phase	Three Phase , 3 / 4 wire
4	Rated Capacitor bank Output	100 KVAR to 3000 KVAR
5	Manual switching device	Vacuum Contactor
6	Incoming disconnecting device	Isolator / VCB
7	Step protection	HRC Fuses
8	Current limiting device	Series Reactor
9	Operating Condition	Indoor / Outdoor
10	Construction	MS Encloser with powder coating
11	Metering	CT / VT



TEST REPORT

SHEET No.: 1 OF 6

NAME & ADDRESS OF CUSTOMER

M/s. JYOTI LTD.
SWITCHGEAR DIVISION
J/44-59, B.I.D.C., Gorwa,
Vadodra-390 016 (India).

TEST REPORT No.: HIMP/04/101
DATE : 27/04/2012

CUSTOMER REF. No. DATE

SWGR- R&D/NP/ERDA/12/01 23/04/2012

DATE OF SAMPLE RECEIPT DATE OF TESTING

23/04/2012 27/04/2012

SAMPLE DESCRIPTION

HT APFC PANEL
Rated Voltage : 6.6 kV
H. S. V. : 7.2 kV
Rated Current : 60 A
No. of Phase : 03
S. T. C. : 26.4 kA for 1 sec. with
initial peak of 66 kA
B. I. L. : 20 kVrms / 60 kVp
Frequency : 50 Hz
Year Of Mfg. : 2012

SAMPLE IDENTIFICATION

ERDA Sample Code No.:

LSCLWO 010760/01

APFC PANEL SERIAL No.:

GP2012-001/A

ENCLOSURES

A) ANNEXURE - 1

B) DRG. No.:

I. 1101100101 Rev.0

II. 1101100102 Rev.0

TEST SPECIFICATION

As per customer's requirement & generally test procedure was followed as per IEC: 60060 - 1 - 2010

TEST DETAILS:

I) LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST AT 60 kVp.

II) DRY POWER FREQUENCY VOLTAGE WITHSTAND TEST AT 20 kVrms.

TEST WITNESSED BY: Mr. P.L. Chaudhari - M/s. Jyoti Ltd.

REMARKS: The above sample CONFORMS to the requirements of aforesaid reference standard with respect to tests carried out.

PREPARED BY: *B. J. Meny*

CHECKED BY: *B. J. Meny*

APPROVED BY: *B. J. Meny*

NOTE: 1. This report relates only to the particular sample received in good condition for testing at ERDA.

2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director, ERDA.

4. Only tests asked for by customer have been carried out.



TEST REPORT

SHEET No.: 1 OF 6

NAME & ADDRESS OF CUSTOMER

M/s. JYOTI LTD.
SWITCHGEAR DIVISION
J/44-59, B.I.D.C., Gorwa,
Vadodra-390 016 (India).

TEST REPORT No.: HIMP/04/102
DATE : 27/04/2012

CUSTOMER REF. No. DATE

SWGR- R&D/NP/ERDA/12/02 27/04/2012

DATE OF SAMPLE RECEIPT DATE OF TESTING

23/04/2012 27/04/2012

SAMPLE DESCRIPTION

HT APFC PANEL
Rated Voltage : 11 kV
H. S. V. : 12 kV
Rated Current : 60 A
No. of Phase : 03
S. T. C. : 26.4 kA for 1 sec. with
initial peak of 66 kA
B. I. L. : 28 kVrms / 75 kVp
Frequency : 50 Hz
Year Of Mfg. : 2012

SAMPLE IDENTIFICATION

ERDA Sample Code No.:

LSCLWO 010760/01

APFC PANEL SERIAL No.:

GP2012-001/A

ENCLOSURES

A) ANNEXURE - 1

B) DRG. No.:

I. 1101100101 Rev.0

II. 1101100102 Rev.0

TEST SPECIFICATION

As per customer's requirement & generally test procedure was followed as per IEC: 60060 - 1 - 2010

TEST DETAILS:

I) LIGHTNING IMPULSE VOLTAGE WITHSTAND TEST AT 75 kVp.

II) DRY POWER FREQUENCY VOLTAGE WITHSTAND TEST AT 28 kVrms.

TEST WITNESSED BY: Mr. P.L. Chaudhari - M/s. Jyoti Ltd.

REMARKS: The above sample CONFORMS to the requirements of aforesaid reference standard with respect to tests carried out.

PREPARED BY: *B. J. Meny*

CHECKED BY: *B. J. Meny*

APPROVED BY: *B. J. Meny*

NOTE: 1. This report relates only to the particular sample received in good condition for testing at ERDA.

2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director, ERDA.

4. Only tests asked for by customer have been carried out.



TEST REPORT

SHEET 1 OF 5

NAME & ADDRESS OF CUSTOMER

JYOTI LTD.
SWITCHGEAR DIVISION
J/44-59, B.I.D.C.,
Gorwa, Vadodra - 390 016, (India).

REPORT No.: LSCM/0112

DATE: 30.04.2012

CUSTOMER REF. NO.: DATED: 23.04.2012

SWGR- R&D/ NP/ERDA/12/01

DATE OF SAMPLE RECEIPT: 23.04.2012

DATE OF TESTING: 25.04.2012

SAMPLE DESCRIPTION

60A, 7.2kV, 750 kVAR HT APFC PANEL
Rated voltage: 7.2 kV,
Rated normal current: 60 A/750 kVAR
Rated frequency: 50 Hz., No. of poles: 3,
Rated insulation level: 20kVrms/60kVpeak
Rated short time withstand current & its duration: 26.4 kArms for 1 sec. with an initial peak of 66 kA
Quantity (Tested): 1 No.
Further details as per sheet No. 3 of 5

SAMPLE IDENTIFICATION

ERDA SAMPLE CODE NO:

LSCLWO 010760/01

SERIAL NO: GP2012-001

DRAWING NO:

1101100101 Rev.0
1101100102-A Rev.0

TEST DETAILS

Short time withstand current and peak Withstand current tests (Cl. No. 6.5) (On Main Circuit)

TEST SPECIFICATIONS

As per customer's requirement, Test procedure followed as per, IEC: 62271-200 (2003)

ENCLOSURES:

Number of oscillograms : One
Number of photograph : One
Number of test circuit diagram : One
Number of drawings : Two

TEST WITNESSED BY: Mr. P. L. Chaudhari

RESULTS: The sample conforms to the requirement of short time withstand current & peak withstand current tests as specified by customer.

PREPARED BY: *B. J. Meny*

CHECKED BY: *B. J. Meny*

APPROVED BY: *B. J. Meny*

NOTE: 1. This report relates only to the particular sample received for testing in good condition at ERDA.

2. This report cannot be reproduced in part under any circumstances.

3. Publication of this report requires prior permission in writing from Director, ERDA.

4. Only tests asked for by customer have been carried out.



FOR FURTHER ENQUIRIES
PLEASE CONTACT

BRANCH
OFFICES

SWITCHGEAR DIVISION
J/44-59, B.I.D.C., Gorwa,
Vadodra-390 016 (India)
Phone : 2280770 (5 lines)
Fax : +91-265-2280153
-2280208
E-Mail : switchgear@jyoti.com
Website : http://www.jyoti.com

• Ahmedabad : 406, Akshat Tower, Opp. Rajpath Club, Havmor Restaurant Lane, Bodakdev, Ahmedabad-380 054. Ph.: 079-26870980, Fax: 079-26871051, Email: ahmedabad@jyoti.com, jyotiahm@gmail.com
• Bangalore : No. 94, 10th Cross, East Park Road, Malleswaram,, Bangalore-560 020. Telefax : 080-23562248
E-Mail : bangalore@jyoti.com
• Chennai : VEE DEE YEM Complex, 1st Floor, 270, Lloyds Road, Royapettah, Chennai 600014, Ph. : 044-28131754, Fax: 044-28133178, E-Mail : chennai@jyoti.com
• Indore : Office No. 502, 5th Floor, Capt. C.S. Naidu Arcade, Nr. Greater kailash Hospital, Old Palasia, Indore 452001. Telefax: 0731-2542621, E-mail : indore@jyoti.com, jyotiindore@rediffmail.com
• Kolkata : 45, Jhowtalla Road, Syed Amir Ali Avenue, Kolkata-700 019, Ph. : 033-22902056, 32487527 Fax: 033-22875267, E-Mail : kolkata@jyoti.com
• Mumbai : Narsinh Sadan, Flat No. 102, 1st Floor, 1st Road, Golibar, Santacruz (East), Mumbai-400 055. Ph.: 022-26134403 (D), 26122848, Fax: 022-26100717, E-Mail : mumbai@jyoti.com
• New Delhi : 7, Jantar Mantar Road, New Delhi-110 001. Ph. : 011-23340576, Telefax : 011-23340205, E-mail : delhi@jyoti.com
• Pune : 244, F. M. City Centre Building, Nalband Associates, Above Dena Bank, Mumbai-Pune Road, Chinchwad, Pune-411 019. Ph.: 020-27472676, Fax: 020-27473077, E-Mail : pune@jyoti.com
• Secunderabad : 5-4-187/7, 1st Floor, Karbala Maidan, M.G.Road, Secunderabad - 500 003. Ph. : 040-27544587(D), 27541608, Fax: 040-27543673, E-Mail : jyotisecc@yahoo.com, jyotisecc@jyoti.com

In keeping with the technological strides the world is making in the engineering field, we introduce changes in the design of our products. Hence, the products as actually supplied might have features varying herefrom. The word 'Jyoti' and 'Jyoti' logo are the registered trademarks of Jyoti Ltd. Vadodra.